

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2134

Dated: 29/5/2026

It is certified that an inspection team headed by AVINASH SINGH PARMARTH (Name of Officers with designation) from P.H.E.D DIVISION, GAYA (Name of Department/Office) inspected THE MAHABODHI TREE, VILL- MATIHANI, PS- MAGADH UNIVERSITY, BODHGAYA (Name & Address of the school) on 20/5/2026 (date of inspection), and on the basis of Water Test report (attached) of District Level Water Testing Lab, GAYA (P.H.E.D LAB) certified that THE MAHABODHI TREE has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The certificate is valid till ONE YEAR

Signature with Seal: AVINASH SINGH PARMARTH
29/5/26
Name: AVINASH SINGH PARMARTH
Designation: EXECUTIVE ENGINEER,
P.H. DIVISION - GAYA

To,

THE MAHABODHI TREE

VILL-MATIHANI, PS-MAGADH UNIVERSITY, BODHGAYA

GAYA, BIHAR - 824234

Name & Address of The Institution

Govt. Of Bihar
 DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
 Public Health Engineering Department
 P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :		THE MAHABODHI TREE Matihani Dobhi Road Bodh Gaya																	
P.K Sharma		Sample Received on : 20/05/26																	
Sample no	Block Name	Panchayat Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+,-)	Remarks
1	Bodh gaya	Bodh gaya	Matihani	-	0.17	290	188	104	30.46	8.75	33.99	124	0.54	7.29	-	-	20	Absent	
Reporting Date :	26.05.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
missible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	

*NR-No Relaxation.,BDL-Below Detection Limit

जल नमूना का संग्रह दिनांक 20.05.26
 R. Boudh के द्वारा किया गया है।

R. Boudh
 26.05.26
 Chemist

P.H.Division, Gaya